



CERTIFICATE OF REGISTRATION

This is to certify that

Pacific Rim Wood Ltd

Pt Kutai Timber Indonesia
Jl. Tanjung Tembaga Baru, Pelabuhan
Probolinggo 67201, Jawa Timur
INDONESIA

UK Registration: Pacific Rim Wood Limited

Meets the requirements of the BM TRADA **Q-Mark Fire Door Manufacture** scheme to **STD006**

Steve Roberts
Product Certification Operations Manager
For and on behalf of BM TRADA

Certificate Number

027

Date of Initial Certification

04/05/2001

Date of Last Issue

02/05/2024

Date of Expiry

03/05/2025

BM TRADA is a trading name of Warringtonfire Testing and Certification Limited, Chiltern House, Stocking Lane, High Wycombe, Buckinghamshire, HP14 4ND, UK
Registered Office: Warringtonfire Testing and Certification Limited, 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA, UK
Reg No. 11371436.

This certificate remains the property of Warringtonfire Testing and Certification Limited. This certificate and all copies or reproductions of the certificate shall be returned to Warringtonfire Testing and Certification Limited or destroyed if requested. Further clarification regarding the scope of this certificate and verification of the certificate is available through BM TRADA or at the above address or at www.bmtrada.com

Registration Schedule

Head Office Address

Pacific Rim Wood Limited
Ground Floor Suite, Block B
Old Kelways,
Somerton Road,
Langport, Somerset
TA10 9SJ
United Kingdom

Factory Address

PT. Kutai Timber Indonesia
Jl. Tanjung Tembaga
Baru
Pelabuhan
Probolinggo 67201
Jawa Timur
Indonesia

Scope

Primary Field of Application (FoA) Reports (owned by this certified company)

Either used in isolation, or can be used in conjunction with an appropriate associated document for this company, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

Certificate Schedule 1						
Type	FoA Report	Rev	System Supplier owner of Assessment Report	Doorset Description	Integrity Period	FoA Standard
Fire	FEA/F981 64	O	Pacific Rim Wood Ltd	Flamebreak Doorsets for 30 minutes Fire Resistance (Glazed or unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-			
Fire	FEA/F021 41	M	Pacific Rim Wood Ltd	Flamebreak 660 Ply Faced and FF660 MDF Faced Doorset Ranges in Timber Based Door Frames for 60 minutes Fire Resistance (Glazed or unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-			
Fire	WF51395 6	-	Pacific Rim Wood Ltd	The Flamebreak 430 Range of Doorsets for 30 minutes Fire Resistance (Glazed or unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-			

Primary Field of Application (FoA) Reports (owned by and cascaded by a System Supplier)

The revision status of each FoA can be verified on the BM TRADA website under each System Supplier's certification entry. They are either used in isolation, or can be used in conjunction with an appropriate associated document for this company, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

Type	FoA Report	System Supplier owner of Assessment Report	Doorset Description	Integrity Period	FoA Standard
Fire	N/A	-	-	-	-
Smoke	N/A	-			

Test Reports

Test reports cannot be used in conjunction with any primary FoA reports, other test reports or associated documents. They must be followed precisely without any deviation whatsoever.

No specification or parameter changes are allowed at all from that stated within the test report such as size, shape, design, glazing, leaf/frame specification, hardware etc.

Test Report	Owner of Test Report	Doorset Description	Rating	Test Standard
N/A	-	-	-	-